


# WEBER STATE UNIVERSITY

# PETERSON PLAZA DFCM PROJECT NO. 05070810




# VICINITY MAP


# LANDSCAPE ARCHITECT


BINGHAM ENGINEERING 5160 WILEY POST WAY SALT LAKE CITY, UTAH 84116 (801) 532-2520


### **SHEET INDEX:**


- S-1 SURVEY CONTROL
- 5-2 PHASING PLAN
- S-3 DEMOLITION PLANS-4 DEMOLITION PLAN
- S\_5 DIMENSION DIAM
- S-6 DIMENSION PLAN
- 5-7 PAVING LAYOUT PLAN
- S-8 SITE PLAN
- -9 SITE PLAN
- S-10 SITE DETAILS
- -11 SITE DETAILS -12 SLEEVING PLAN
- S-13 GRADING PLAN
- -14 WALL SECTIONS
- S-15 WALL ELEVATIONS S-16 WALL ELEVATIONS
- S-17 DRAINAGE PLAN
- S-18 DRAINAGE DETAILS
- 5-19 DRAINAGE DETAILS
- -1 MAINLINE PLAN
- -2 IRRIGATION PLAN
- 3 IRRIGATION PLAN
- I-4 IRRIGATION NOTES AND SCHEDULE
- 5 IRRIGATION DETAILS
- -6 IRRIGATION DETAILS
- PLANTING PLAN-TREES
- 7-2 PLANTING PLAN-TREES
- -3 PLANTING PLAN SHRUBS
- -4 PLANTING PLAN SHRUBS
- P-5 PLANTING PLAN WEED BARRIER FABRIC PLACEMENT
- P-6 PLANTING SCHEDULE & DETAILS
- -7 PLANTING NOTES & DETAILS
- E-1 LIGHTING PLAN





























### CONTROL JOINT


(1) EDGE EACH SIDE W/ 1/4" RADIUS

- 2) 1/2" FELT EXPANSION MATERIAL. SEAL TOP W/ BACKER ROD & JOINT SEALANT (COLOR TO MATCH PAVING COLOR)
- (3) SAWCUT ON ALL HORIZONTAL SURFACES, HAND FORM ON ALL VERTICAL SURFACES AS REQUIRED.

CONCRETE PAVING NTS COPYRIGHT (c) 2005 by Bingham Engineering

- (1) 6" CONCRETE PAVING W/ MEDIUM BROOM FINISH
- (2) 6" UNTREATED BASE COURSE (3/4" MINUS)
- (3) UNDISTURBED OR 95% COMPACTED SUBGRADE
- (4) CONTROL JOINT SEE ACCOMPANYING DETAIL (S9)

NOTE: ALL CONCRETE FLAT WORK SHALL CONTAIN FIBERGLASS REINFORCEMENT PER WEBER STATE UNIVERSITY CONCRETE SPECIFICATIONS. NOTE DOES NOT APPLY TO COLOR STAMPED CONCRETE.



NOTE: SEE PLANS FOR SPECIFIC COLORS AND PATTERN,

## COLOR STAMPED CONCRETE NTS COPYRIGHT (c) 2005 by Bingham Engineering


- COLOR STAMPED FINISH COLOR SHALL BE INTEGRAL IN THE BASE CONCRETE MIX. PLACE COLORING AGENT AT BATCH PLANT, APPLY ANTIQUING RELEASE AGENT PER MANUFACTURER'S RECOMMENDATIONS. USE THE SPECIFIED COLORS WITH SPECIFIED LITHATEX PATTERN - MATCHED TOOLS FOR TEXTURING SURFACE OF FRESHLY PLACED CONCRETE, CONTRACTOR SHALL PREPARE A 5'X5' SAMPLE FOR OWNER'S APPROVAL PRIOR TO INSTALLATION. INSTALL PER MANUFACTURER RECOMMENDATIONS. COLOR AND PATTERN SHALL BE DETERMINED BY OWNER IN CONSULTATION WITH CONCRETE CONTRACTOR.
- (2) 6" CONCRETE SLAB.
- 6" ROAD BASE COMPACTED TO 95% DENSITY.
- UNDISTURBED OR 95% COMPACTED SUBBASE.

NOTE: ALL COLORED, STAMPED CONCRETE CELLS (19' X 19' max) SHALL BE POURED FROM A SINGLE TRUCK. NO CONCRETE MIXING IN CELLS WILL BE ALOWED.


# **SLAB JOINTS**

NTS COPYRIGHT (c) 2005 by Bingham Engineering

- 12" TOPSOIL (TYP.)
- (2) BASE SHALL BE THOROUGHLY COMPACTED TO 95% RELATIVE DENSITY BEFORE BOULDERS ARE PLACED
- 3 BOTTOM ROCKS SET 2' BELOW FINISH GRADE
- 4 95% COMPACTED SUBGRADE (USE SITE SOIL WHERE POSSIBLE)



- (1) EXISTING GRADE-SLOPE VARIES
- (3) PROPOSED GRADE-SLOPE VARIES
- (2) 1" GRAVEL DRAINAGE AREA
- (4) EXISTING SITE SOIL




**GRAVEL DRIP ZONE** 

- 1) 12 X 6 INCH CONCRETE BANDING (MIN 2000 PSI AT 28 DAYS)
- (2) COLOR STAMPED CONCRETE (see detail above)
- (3) 1/2" RADIUS TROWELED EDGES (TYP.)
- (4) #3 REBAR CONT. (LAP 12" AT SPLICES)
- 6" ROAD BASE COMPACTED TO 95% DENSITY.
- 6 UNDISTURBED OR 95% COMPACTED SUBGRADE
- (1) 6 INCH SQUARE CONCRETE MOW STRIP (MIN 2000 PSI AT 28 DAYS)
- 2) FINISH GRADE AT 2" FOR GROUNDCOVER AREAS
- (3) FINISH GRADE FOR LAWN AREAS: 1" FOR SEED; 1 1/2" FOR SOD
- -R=2" VARIES - SEE PLAN (14)— ±24.00" ±36.00" **SEAT WALL** NTS COPYRIGHT (c) 2005 by Bingham Engineering
- (4) 1/2" RADIUS TROWELED EDGES (TYP.)
- #3 REBAR CONT. (LAP 12" AT SPLICES)
- 6 UNDISTURBED OR 90% COMPACTED SUBGRADE
- (7) 2" LAYER SHREDDED BARK MULCH IN PLANTER BEDS

- PRE-FABRICATED CONCRETE CAP AS MANUFACTURED BY MODERN PRECAST, INC. CONTACT BRUCE @ (801)466-1374. INSTALL CAP SO AS TO DRAIN MINIMALLY BACK INTO PLANTING AREA. INSTALL CAP PER MANUFACTURER'S RECOMMENDATIONS.
- (2) TOP SOIL IN PLANTER
- (3) 2 1/2"x16"x8" ATLAS BLOCK WALL GOLDEN BUFF GROUT 100%. AS MANUFACTURED BY INTERSTATE BRICK. CONTACT ALAN HAWS @ (801) 233-8654.
- (4) PLACE 6"x6" W2.9xW2.9 HORIZONTAL MESH @ 6" O.C. VERTICALLY (EVERY OTHER BLOCK)
- (5) 8"x16"x8" STANDARD CMU BLOCK BELOW GRADE ONLY GROUT 100%.
- (6) #4 HORIZONTAL REBAR 24" O.C., MINIMUM OF 1.
- (7) #5 VERTICAL REBAR 15" O.C.
- (8) 2" CONSTRUCTION KEY
- (9) #5 "J" REBAR @ 15" O.C.
- (10) CONCRETE FOOTING
- (11) 3 #5 REBAR CONT.
- (12) COMPACTED SUBBASE 95%
- (13) 6" COMPACTED ROADBASE
- (14) 6" CONCRETE PAVING COLORED & STAMPED FINISH
- (15) 6" CONCRETE BORDER MEDIUM BROOM FINISH, 18" WIDTH
- (16) 1/2" FELT EXPANSION JOINT
- WATERPROOF MEMBRANE WATCHDOG POLYMER-ENHANCED ASPHALT LIQUID—APPLIED MEMBRANE (OR APPROVED EQUAL). INSTALL FROM FOOTING TO SOIL LEVEL, BACK SIDE OF WALLS. INSTALL PER MANUFACTURER'S RECOMMENDATIONS.


P:\4365\4365-PROJECT\dwg\4365-DETAILS.dwg

(18) WALL DRAIN (see details)



NOTE: PROVIDE CONSTRUCTION OR CONTROL JOINTS AND


EXPANSION JOINTS AS SHOWN ON PLANS.




COPYRIGHT (c) 2005 by Bingham Engineering


NOTE: PROVIDE CONSTRUCTION OR CONTROL JOINTS AT 5' O.C. MAX. AND EXPANSION JOINTS WHERE CONCRETE MOWSTRIP


MOWSTRIP ABUTS ANY MASONRY TYPE IMPROVEMENT.





Rev. By Date Remarks



















B C D L Z

NOTE: THESE FOUNDATION STEPS SHALL BE CONSIDERED BY THE CONTRACTOR TO BE SCHEMATIC IN NATURE, AND MAY REQUIRE ADJUSTMENTS DURING INSTALLATION IN THE FIELD. THE CONTRACTOR MAY MAKE CHANGES THAT MORE CLOSELY FOLLOW BEST PROFESSIONAL STANDARDS TO ACCOMPLISH THE DESIGN INTENT OF THESE DRAWINGS. THE STEPPING OF FOOTINGS AND WALL HEIGHTS IS INTENDED TO REDUCE THE AMOUNT OF WALL TO BE BUILT, AND PROVIDE THE MOST EFFICIENT CONSTRUCTION POSSIBLE.

SEE CONSTRUCTION DETAIL FOR EXACT WALL CONSTRUCTION.

NO STANDARD CMU BLOCK SHALL BE VISIBLE ABOVE FINISHED GRADE. ALL COURSES SHALL BE INSTALLED LEVEL.







SCALE (FT)


0 4 8 12


# WEBER STATE UNIVERSITY PETERSON PLAZA


ATLAS BLOCK WALLS PROPOSED ELEVATIONS

BINGHAM DE CHANGE CHANG


GHG	03/24/06	DFCM REVISIONS	Print Date: 03/24/2006	Created:05/19/05		Proj. # 4365	
GHG	06/03/05	ISSUED FOR BID	Copyright © 2003 Bingham Engineering, Inc. Drawing not to be reused in or in whole without written permission.				
B∨	Date	Remarks	P:\4365\4365-PROJECT\dwa\43	65-WALL X	SECTION dwa	RKC	







- $\bigcirc$   $\frac{1}{4}$ "  $\times$   $\frac{1}{2}$ "  $\times$  1" grinding pads for final LEVELING
- 3 TEMPORARY SPREADERS SPOT WELDED TO TROUGH REMOVE AFTER CONCRETE SETS
- (4) FORMED STEEL TROUGH 16 GAUGE. SET @ 0.75% SLOPE (SEE GRADING PLAN FOR DETAILS).



CLEAR OPENINNG (D) IS 2" LESS THAN GRATE WIDTH (A)

WELDED TO FORMS, (24" O.C. typ.)

TROUGH OPENING (B) IS 1/4"GREATER THAN GRATE WIDTH (A)

INSTALL SPREADERS 1/4" LARGER THAN GRATE WIDTH (B) AT 18" MINIMUM CENTERS WHEN POURING CONCRETE TO INSURE PROPER FIT.

DEPTH (E) CAN BE SPECIFIED, (BOTTOM PROFILE OF TROUGH MAY VARY DEPENDING ON DEPTH).

TROUGHS ARE SUPPLIED IN 5' MAXIMUM SECTIONS

TROUGH AND GRATE SHALL BE PREFORMED WITH GRATE TO HAVE AN INTERIOR RADIUS OF 34'-3"

END CAPS AND PIPE CUTOUTS AVAILABLE ON REQUEST


TROUGHS ARE NOT WATER TIGHT AND ARE DESIGNED TO ASSIST IN CONCRETE FORM UP.

ORDER GRATE, FRAME, AND TROUGH FROM:


IRONSMITH 41-651 Corporate Way #2&3 Palm Desert, CA 92260 (800) 338-4766 (760) 776—5080 Fax

## TRENCH DRAIN SECTION


Α	В	С	D
6"	6 3/4"	6 1/4"	4 1/4"



### TRENCH DRAIN AT SEAT WALL







STANDARD DESIGN "A"

MANHOLE CASTING D & 1

<u>PLAN</u>

1180 OR AN APPROVED

EQUIVALENT WITH

REMOVAL HOLES

TRENCH DRAIN OUTLET NTS COPYRIGHT (c) 2005 by Bingham Engineering (1) PLANTER WALL

D & L 1180 OR AN EQUALIVALENT M.H. RING

& VENTED COVER WITH

DUST PAN COVER TO

HAVE REMOVAL HOLES

FINISH GRADE

INSTALL GRADE RINGS -

AS REQUIRED.

USE MASTIC

MATERIAL AS

PROVIDED BY -

MANUFACTURER.

SET BOTTOM SECTION ON

BLOCKS PRIOR TO POURING

CLEARANCE ABOVE SEWER

PRE-CAST BASES ARE

PIPE. (OPTIONAL

ACCEPTABLE.)

MANHOLE AND INLETS

NTS COPYRIGHT (c) 2005 by Bingham Engineering

CONCRETE BASE. 1/4" MIN.-

- 2 PAVING
- (3) FINISHED GRADE INSIDE PLANTER
- 4 TOPSOIL
- (5) 6" MIN. COARSE SAND AROUND DRAIN PIPE
- (6) 4" PERFORATED ADS DRAIN PIPE WITH SOCK
- 7 SUB GRADE TOPSOIL INTERFACE. GRADE 2% TOWARD DRAIN
- (8) PIPE FITTINGS HDPE TEE TO SDR 35 PVC
- 9 CORE DRILL THROUGH WALL TO ACCOMMODATE PIPE SEAL AROUND PIPE WITH GROUT

STEPS

CHAINED TO MANHOLE -WALL W/STAINLESS

STEEL CHAIN

VARIES 4' TO 5'

AS SHOWN ON PLAN

ELEVATION DROP PER PLANS

OR DISTRICT ENGINEER

OUTSIDE DROP MANHOLE

- (10) WATERPROOF MEMBRANE SEE DETAIL C/S-11
- (1) SUBGRADE
- (2) 4" SDR DRAIN AND FITTINGS
- (3) 4" PVC OUTLET
- (4) 6" UNTREATED BASE COURSE (3/4" MINUS)
- (5) TRENCH DRAIN see detail
- (6) 1/2" FELT EXPANSION JOINT



**PETERSON PLAZA** 

WEBER STATE UNIVERSITY

NOTES: FINISH FLOOR WHEN CONC.

BASE IS POURED. CUT TOP ½
OF PIPE OUT AFTER CONC. HAS
SET TO 3" FROM WALLS.

GROUT FACE OF CHANNEL TO COVER EDGE OF PIPE.

6" TRENCH FOUNDATION

GRAVEL


18" SCARIFY & RECOMPACT


**DRAINAGE DETAILS** 


BBING

NGHAM	Den:	JIII.	_	
GINEERING	Drw:		<b>3</b> _'	1
CITY - (BO1) 532-2520	Chk:	•	<b>)</b> -	
- (BO1) <b>399-1662</b>	Rvw:	of	19	

1 GHG 03/24/06 DFCM REVISIONS Created: 01/01/01 Proj. # 4365 0 GHG 06/03/05 ISSUED FOR BID Print Date: 03/24/2006Copyright © 2003 Bingham Engineering, Inc. Drawing not to be reused in part or in whole without written permission. B GHG 05/13/05 ISSUED FOR REVIEW Rev. By Date Remarks P:\4365\4365-PROJECT\dwg\4365-DRAINAGE.dwg







### **IRRIGATION NOTES**

1. IRRIGATION PLAN IS DIAGRAMMATIC. ALL IRRIGATION EQUIPMENT SHALL BE LOCATED IN PLANTING AREAS ONLY, UNLESS NOTED OTHERWISE. REFER TO THE IRRIGATION LEGEND, DETAILS, AND SPECIFICATIONS FOR EQUIPMENT AND INSTALLATION, SPECIFICATIONS SHALL TAKE PRECEDENCE OVER INSTALLATION DETAILS.

LANDSCAPE CONTRACTOR SHALL VERIFY LOCATION OF IRRIGATION POINT OF CONNECTION (POC) AND THE STATIC WATER PRESSURE AT THAT LOCATION PRIOR TO BEGINNING ANY IRRIGATION WORK. IF THE LOCATION OR WATER PRESSURE IS DIFFERENT THAN THAT EXPRESSED BY THE LANDSCAPE ARCHITECT, OR IF THE PRESSURE APPEARS TO BE UNUSUALLY HIGH OR LOW, THE CONTRACTOR SHALL NOTIFY THE LANDSCAPE ARCHITECT IMMEDIATELY.

3. CONTRACTOR SHALL KEEP THE PREMISES CLEAN AND FREE OF EXCESS EQUIPMENT, MATERIALS AND RUBBISH INCIDENTAL TO WORK OF THIS SECTION.

- 4. PIPE FITTINGS SHALL BE AS FOLLOWS:
- A. ALL RISERS AND EXPOSED FITTINGS SHALL BE P.V.C. SCHEDULE 80.
- B. ALL UNDERGROUND FITTINGS SHALL BE P.V.C. SCHEDULE 40.
- C. ALL MAIN LINE TWO AND HALF (2 ½) INCH OR GREATER SHALL USE DUCTILE IRON FITTINGS. ALL MAINLINE TWO (2) INCH OR SMALLER SHALL USE PVC FITTINGS.

#### 5. IRRIGATION CONTROL WIRES SHALL CONFORM TO THE FOLLOWING:

A. ALL WIRE SHALL BE TYPE UF, 600 VOLT, SOLID COPPER, SINGLE CONDUCTOR WIRE. IT SHALL BE UL LISTED, DIRECT BURIAL TYPE, AND MINIMUM SIZE OF 14 GAUGE. ALL SPLICES AND CONNECTIONS SHALL BE WATER—TIGHT. ALL WIRES SHALL BE INSTALLED WITH TWO (2) FEET OF EXCESS WIRE (COILED) AT THE END OF EACH WIRE RUN, WIRE SPLICE, AND AT EACH CONTROLLER.

B. CONTROL WIRE SHALL BE BUNDLED EVERY 10' AND PLACED ADJACENT TO MAIN LINE. ALL WIRE SPLICES SHALL BE LOCATED IN VALVE BOXES.

6. FILTER SHALL BE INSTALLED PER DETAIL SHOWN. PROVIDE PERMANENTLY ATTACHED HOSE (10' LENGTH) FROM FILTER EXHAUST PORT TO DIRECT FLUSHING WATER AWAY FROM FILTER ASSEMBLY AND TOWARDS APPROPRIATE DRAINAGE LOCATION.

7. MANUAL DRAIN VALVES SHALL BE PLACED ON THE MAIN LINE AT ALL LOW SPOTS TO ENSURE COMPLETE DRAINAGE AND WINTERIZATION OF MAIN LINE, ALL MANUAL DRAINS SHALL BE PLACE IN SEPARATE VALVE BOXES PER INSTALLATION DETAILS.

B. CHECK VALVES SHALL BE USED WHERE INDICATED AND WHERE NECESSARY TO PREVENT WATER FLOW FROM LOWER ELEVATION HEADS WHEN SYSTEM IS TURNED OFF, INSTALL PER MANUFACTURE'S RECOMMENDATION, WITH A ONE (1) CU. FT. MIN, GRAVEL SUMP AROUND EACH CHECK VALVE,

9. ALL POP-UP SPRAY SPRINKLERS SHALL CONFORM TO THE FOLLOWING UNLESS SPECIFICALLY NOTED OTHERWISE ON THE PLANS:

- A. SPRINKLERS LOCATED IN GRASS AREAS SHALL BE FOUR (4) INCHES IN HEIGHT.
- B. SPRINKLERS LOCATED IN PLANTING BEDS SHALL BE TWELVE (12) INCHES IN HEIGHT.

10. ALL PRESSURE MAIN LINES SHALL BE EIGHTEEN (18) INCHES TO THIRTY (30) INCHES DEEP, AND ALL LATERAL LINES SHALL BE EIGHT (8) INCHES TO FOURTEEN (14) INCHES DEEP. TRENCH BEDDING AND BACKFILL MATERIAL SHALL BE EXISTING SITE SOIL FREE OF ROCKS, DEBRIS, ETC. GREATER THAN ONE (1) INCH IN ANY DIMÉNSION THAT MAY DAMAGE IRRIGATION PIPE OR EQUIPMENT. IN THE EVENT OF BACKFILL SETTLEMENT, CONTRACTOR SHALL PERFORM REQUIRED REPAIRS AT HIS OWN COST.

11. WHERE POSSIBLE, ALL AUTOMATIC CONTROL VALVES SHALL BE LOCATED WITHIN SHRUB AREAS AND INSTALLED IN GREEN VALVE BOXES, ONE VALVE PER BOX, WITH FOUR (4) INCHES OF 3/4" GRAVEL BENEATH THE VALVE. NO VALVE MANIFOLDS SHALL BE ALLOWED, GATE VALVES SHALL BE LOCATED IN SEPARATE VALVE BOXES. WIRE SPLICES SHALL ALSO BE LOCATED IN SEPARATE VALVE BOXES.

12. ALL MAIN LINE AND LATERAL LINES SHALL BE SLEEVED WITH P.V.C. SCHEDULE 40 PIPE (4" AND UNDER) OR CLASS 200 (GREATER THAN 4") WHERE THEY PASS UNDER PAVED AREAS. SLEEVE SIZE SHALL BE TWCE THE DIAMETER OF THE LINE TO BE SLEEVED UNLESS OTHERWSE NOTED ON THE PLANS.

13. AUTOMATIC CONTROLLERS SHALL BE OF THE SIZE AND TYPE NOTED, AND INSTALLED WHERE INDICATED ON IRRIGATION PLAN. CONTROL WIRES SHALL BE SLEEVED IN ELECTRICAL CONDUIT TO MAINLINE. 120-VOLT ELECTRICAL SERVICE TO CONTROLLERS SHALL BE PROVIDED BY THE LANDSCAPE CONTRACTOR. COORDINATE THIS WORK WITH ELECTRICAL AND OTHER CONTRACTORS FOR THIS PROJECT.

14. A MASTER VALVE SHALL BE INSTALLED ALONG WITH APPROPRIATE FLOW SENSING EQUIPMENT TO ELIMINATE EXCESS SYSTEM FLOW SHOULD A VALVE STICK OPEN AFTER A CYCLE HAS BEEN COMPLETED OR A MAIN LINE BREAK OCCURS.

#### 15. PRIOR TO BACKFILLING IRRIGATION TRENCHES:

A. ALL MAIN LINES IN THE SYSTEM SHALL BE CAPPED AND PRESSURE TESTED AT 125 P.S.I. FOR A PERIOD OF FOUR (4) HOURS. ANY LEAKS FOUND SHALL BE CORRECTED BY REMOVING THE LEAKING PIPE OR FITTINGS AND INSTALLING NEW MATERIAL IN ITS PLACE. REPEAT PRESSURE TEST TO ASSURE ABSENCE OF LEAKS. B. ALL LATERAL LINES SHALL BE PRESSURE TESTED AT DESIGN PRESSURE FOR ONE (1) HOUR. DESIGN PRESSURE FOR THIS PROJECT IS 60 PSI.

C. THE CONTRACTOR SHALL NOT ALLOW NOR CAUSE ANY OF HIS WORK TO BE COVERED UNTIL IT HAS BEEN INSPECTED, TESTED AND APPROVED BY THE OWNER/OWNER'S AUTHORIZED REPRESENTATIVE.

D. WHERE MAIN LINE WILL BE ALLOWED TO SIT UNCOVERED FOR ANY LENGTH OF TIME IN THE TRENCH PRIOR TO TESTING, SHADE MAIN LINE WITH A THIN COVERING OF SOIL TO MINIMIZE WEATHER-RELATED EXPANSION OR CONTRACTION OF PIPE.

16. IRRIGATION CONTRACTOR SHALL ADJUST ALL HEADS TO PROVIDE A UNIFORM COVERAGE AND TO KEEP SPRAY OFF BUILDINGS, WALLS, PARKING AREAS, AND DRIVES.

17. WHEN THE SPRINKLER SYSTEM IS COMPLETED THE CONTRACTOR SHALL, IN THE PRESENCE OF THE OWNER/OWNER'S AUTHORIZED REPRESENTATIVE, PERFORM A COVERAGE TEST OF WATER PROVIDED TO THE PLANTING AREAS TO ENSURE IT IS CONSISTENT AND UNIFORM. THE CONTRACTOR SHALL FURNISH ALL MATERIALS AND PERFORM ALL WORK REQUIRED TO CORRECT ANY INADEQUACIES OF COVERAGE AT HIS OWN COST,

INSTALLED. THESE ARE TO BE DELIVERED ON OR BEFORE FINAL INSPECTION.

18. THE CONTRACTOR SHALL FURNISH TO THE OWNER A COMPLETE "AS BUILT" DRAWING ON MYLAR AND TWO PRINTS SHOWING EXACT LOCATIONS OF ALL ITEMS

19. A REDUCED IRRIGATION PLAN INDICATING ALL SYSTEMS AND THEIR APPROPRIATE SEQUENCED VALVES SHALL BE LAMINATED IN MYLAR AND MOUNTED ON THE INSIDE COVER OF THE IRRIGATION CONTROLLER(S).

20. IRRIGATION CONTRACTOR SHALL MAINTAIN THE SYSTEM FOR THE DURATION OF THE CONTRACT PERIOD.

21. IRRIGATION CONTRACTOR SHALL GUARANTEE THE ENTIRE IRRIGATION SYSTEM TO BE FREE OF DEFECTS IN WORKMANSHIP AND MATERIALS FOR A PERIOD OF ONE (1) YEAR FROM FINAL ACCEPTANCE BY THE OWNER.

#### IRRIGATION MAINTENANCE NOTES

IT IS THE OWNER'S RESPONSIBILITY TO SUPPLY THESE PLANS WITH THE FOLLOWING NOTES AND SPECIFICATIONS, ALONG WITH CONTRACTOR DRAWN "AS BUILT" PLANS TO ANY AND ALL FUTURE OWNERS AND MAINTENANCE COMPANIES.

1. THE PURPOSE OF THIS SPRINKLER SYSTEM IS TO PROVIDE ONLY SUFFICIENT WATER TO MAINTAIN PLANT LIFE DURING DRY WEATHER CONDITIONS OR SUMMER SEASONS. TIME CLOCKS SHALL BE READJUSTED CONTINUOUSLY THROUGHOUT THE SEASON, ON A WEEKLY BASIS IF NECESSARY, TO PROVIDE WATER ONLY WHEN THE SOIL IS DRY AT A DEPTH OF FOUR (4) INCHES THE FIRST INITIAL GROWING SEASON AND SIX (6) INCHES THE FOLLOWING YEARS. IF THE GROUND IS MOIST EITHER AT THE SURFACE OR A DEPTH OF FOUR (4) INCHES DURING THE FIRST YEAR AFTER INITIAL PLANT ESTABLISHMENT, OR IS MOIST AT A DEPTH OF SIX (6) INCHES THEREAFTER, SHUT THE TIME CLOCKS OFF AND DO NOT APPLY ADDITIONAL WATER UNTIL SOIL HAS BEEN ALLOWED TO DRY. READJUST TIME CLOCK PRIÓR TO TURNING VALVES BACK ON. IF RAIN IS FORECAST OR IS EMINENT, ALL IRRIGATION SYSTEMS SHALL BE SHUT OFF AND NOT REACTIVATED UNTIL THE SOIL HAS DRIED TO THE ABOVE DEPTHS.

2. IF ANY SUBSURFACE DRAINAGE OR RUN-OFF IS VISIBLE AT LOW AREAS, ACROSS SIDEWALKS OR AT LOWER PORTIONS OF SLOPES, IMMEDIATELY SHUT THE VALVES OFF TO ALLOW THE AREA TO COMPLETELY DRY OUT. IF THIS CONDITION CONTINUES AFTER SUBSEQUENT WATERINGS, A QUALIFIED GEOLOGIST OR GEOTECHNICAL ENGINEER MUST BE RETAINED TO PROVIDE RECOMMENDATIONS TO ELIMINATE SUBSURFACE WATER OR DRAINAGE PROBLEMS. IF DURING NORMAL IRRIGATION, PONDING TAKES PLACE ON ANY LANDSCAPE AREA. DRIVES, PARKING AREAS OR ANY OTHER AREA. THE IRRIGATION SYSTEM SHALL BE IMMEDIATELY SHUT OFF AND A LICENSED CIVIL ENGINEER SHALL BE IMMEDIATELY CONTACTED TO PROVIDE RECOMMENDATIONS FOR POSITIVE AND PROPER DRAINAGE.

3. INSPECTIONS OF IRRIGATION SYSTEM SHALL BE MADE ON A DAILY BASIS TO OBSERVE AND PROVIDE REPAIRS OR REMEDIES TO THE FOLLOWING UNACCEPTABLE

PROBLEMS: A. OVER-SPRAY ON SIDEWALKS, STREETS, PAVED AREAS, PARKING AREAS, FENCES, WALLS, BUILDINGS OR STRUCTURES.

B. DRAINAGE OR RUN-OFF ACROSS SIDEWALKS, PAVING OR STREETS. C. DAMAGED OR IMPROPERLY OPERATING HEADS, PIPING, VALVES, CONTROLLERS OR OTHER IRRIGATION EQUIPMENT

D. IMPROPERLY ADJUSTED OR OPERATING MOISTURE SENSORS.

4. ONLY LICENSED AND QUALIFIED LANDSCAPE CONTRACTORS AND LANDSCAPE MAINTENANCE INDIVIDUALS SHALL PROVIDE OR MAKE REPAIRS TO IRRIGATION SYSTEM.

5. AT ALL TIMES, THE LANDSCAPE CONTRACTOR OR MAINTENANCE CONTRACTOR SHALL ASSIGN A QUALIFIED INDIVIDUAL OR INDIVIDUALS TO INSPECT AND MONITOR THE IRRIGATION SYSTEM. OWNERS SHALL BE SUPPLIED WITH 24 HOUR EMERGENCY PHONE NUMBERS FOR USE IN REPORTING BROKEN OR DAMAGED IRRIGATION EQUIPMENT.

6. ALL IRRIGATION EQUIPMENT REQUIRES CONTINUOUS MAINTENANCE, CLEANING, ADJUSTMENT, PARTS REPLACEMENT AND INSPECTION. IT IS THE RESPONSIBILITY OF THE LANDSCAPE CONTRACTOR OR LANDSCAPE MAINTENANCE COMPANY TO PROVIDE THESE SERVICES ON A CONTINUAL AND REGULAR BASIS AND SCHEDULE.

7. WATER SHALL BE APPLIED TO PLANTING AREAS IN SHORT INTERVALS OR MOISTURE SENSORS SHALL BE ADJUSTED TO PROHIBIT ANY SURFACE PONDING OR RUN-OFF, AND AT NO TIME SHALL WATER BE APPLIED TO CAUSE SOIL SATURATION.

8. OVERWATERING CAN RESULT IN DEATH OF PLANTS, POSSIBLE SOIL EXPANSION AND DAMAGE TO CONCRETE AND ASPHALT PAVING, DAMAGE TO FOUNDATIONS AND POSSIBLE LOSS OF SOIL COMPACTION. A QUALIFIED GEOTECHNICAL ENGINEER SHALL BE RETAINED TO PROVIDE SITE INSPECTIONS AT LEAST ON AN ANNUAL BASIS TO INSPECT FOR EXCESS SOIL MOISTURE.

ENSURING THAT THE ABOVE PRECAUTIONS, REPAIRS AND CONTINUING MAINTENANCE ARE PROPERLY PERFORMED IS THE RESPONSIBILITY OF THE OWNER. THE LANDSCAPE ARCHITECT HAS BEEN RETAINED TO PREPARE THESE PLANS ONLY. AND DOES NOT PROVIDE POST CONSTRUCTION REVIEWS NOR REVIEWS OF ON-SITE MAINTENANCE. THE LANDSCAPE ARCHITECT DOES NOT ASSUME RESPONSIBILITY NOR LIABILITY OF MAINTENANCE OR REVIEW OF MAINTENANCE WORK OR REPAIRS OR DAMAGES RESULTING FROM LACK OF REPAIRS, MAINTENANCE, ADJUSTMENTS OR IMPROPER INSTALLATION OF IRRIGATION EQUIPMENT,

### IRRIGATION EQUIPMENT SCHEDULE

\$YML	MANUF.	MODEL NUMBER	DESCRIPTION	PSI	GPM	RADIUS
0	HUNTER	INST-04-CV-10A	POP-UP SPRAY SPRINKLER & NOZZLE	30	VARIES	10
•	33	INST-04-CV-10Q	נל ענ ננ נג	30	0.49	10'
igodot	11	INST-04-CV-10H	25 25 25	30	0.97	10'
0	HUNTER	INST-04-CV-10F	POP-UP SPRAY SPRINKLER & NOZZLE	30	1.95	10'
	HUNTER	INST-04-CV-12A	POP-UP SPRAY SPRINKLER & NOZZLE	30	VARIES	12
	33	INST-04-CV-12Q	n 11 11 11	30	0.71	12'
	11	INST-04-CV-12H	M 11 17 M	30	1. <del>4</del> 2	12' SPRAY HEADS IN LAWN
	HUNTER	INST-04-CV-12F	POP-UP SPRAY SPRINKLER & NOZZLE	30	2.85	12' AREAS TO BE 4" POP-UPS, ALL OTHERS
<b>V</b>	HUNTER	INST-04-CV-15A	POP-UP SPRAY SPRINKLER & NOZZLE	30 	VARIES	15' / TO BE 12" POP-UPS
<b>V</b>	" HUNTER	INST-04-CV-15Q INST-04-CV-15H	POP-UP SPRAY SPRINKLER & NOZZLE	30 30	0.93 1.86	15' 15'
$\nabla$	HUNTER	INST-04-CV-17A	POP-UP SPRAY SPRINKLER & NOZZLE	30	VARIES	17'
$\bigcirc$					-	
<b>(A)</b>	HUNTER	INST-12-CV-body	POP-UP ROTOR SPRINKLER & NOZZLE	15	0 47 0 70	45 001
_		MP2000 90-210 nozzle	M 11 15 M	45	0.47-0.78	15-20
B)	HUNTER	INST-12-CV-body	91 11 19 NI	4.5	4 4 7	45 00
WALLA WALLA	HUNTER CO.	MP2000 210-270 nozzle INST-12-CV-body	19 55 51	45	1.17	15–20'
		MP2000 360 nozzle	POP-UP ROTOR SPRINKLER & NOZZLE	45	1.56	15-20'
	SI MINICELL CO.	WII 2000 300 HGZZIE	TOT OF NOTON STRUMLEN & NOZZEE	+0	1.00	10 20
<b>(</b>	HUNTER	INST-12-CV-body	POP-UP ROTOR SPRINKLER & NOZZLE			
_		MP3000 90-210 nozzle	31 11 19 31	45	0.91-1.93	23-30'
Ð	HUNTER	INST-12-CV-body	19 99 96 HS			
WALLA WALLA	SPRINKLER CO.	MP3000 360 nozzle	POP-UP ROTOR SPRINKLER & NOZZLE	45	3.86	23–30'
<b>©</b>	HUNTER	INST-12-CV-body	POP-UP ROTOR SPRINKLER & NOZZLE			
		MP1000 90-210 nozzle	101 01 101010 31 1111111111 02 14022EE	45	0.20-0.40	11-14
Willy Willy	or minitely oo,	WII 1000 00 210 1102210		10	0,20 0,10	
A	HUNTER	I-20-ADV-1.0(Q)	POP-UP ROTOR SPRINKLER & NOZZLE	50	1.2	21-31'
$\bigwedge$	<b>77</b>	I-20-36V-1.0(F)	מ זנ ננ מ	50	1.2	21-31'
<u> </u>	33	I-20-ADV-2.0(H)	וא יונ נו ני	50	2.0	26-36'
Â	HUNTER	I-20-36V-2.0(F)	POP-UP ROTOR SPRINKLER & NOZZLE	50	2.0	26-36'
<u> 310</u>	HUNTER	1-20-ADV-3.0(Q)	POP-UP ROTOR SPRINKLER & NOZZLE	50	2.7	29-38'
<u> </u>	"	I-20-ADV-6.0(H)	ח ונ ני ח	50	5.5	32-43'
<u></u>	HUNTER	I-20-36V-6.0(F)	POP-UP ROTOR SPRINKLER & NOZZLE	50	5.5	32-43'
	RAINBIRD	EFB-CP-PRS-D	ELECTRIC BRASS REMOTE CONTROL VALVE A	SSEMBLY WIT	H PRFSSURF	F REGULATION (see plans for sizes)
lacktriangle						
igoplus	RAINBIRD	EFB-CP	ELECTRIC BRASS REMOTE CONTROL VALVE A	SSEMBLY (se	e plans for	sizes)
0	HUNTER	HCV	CHECK VALVE PLACED AT EVERY EIGHT FEET	OF ELEVATION	ON CHANGE	
•	RAINBIRD	44LRC	QUICK COUPLING VALVE ASSEMBLY (including	g key and sv	vivel hose e	ell)
Т	FORD	B11-333	MANUAL DRAIN VALVE ASSEMBLY			
×	NIBCO		RESILIENT SEAT GATE VALVE, NON-RISING ST	ΓΕΜ (line size	e)	
$\bowtie$	RAPHAEL	C-040-32-636	4" MASTER CONTROL VALVE ASSEMB 2-WAY BRASS PILOT, GREEN SPRING	•	ILLY OPEN	I, PRESSURE REGULATING,
F	AMIAD	2-0420-1110-4030	4" SUPER STEEL INLINE FILTER ASSEMBLY V AND WEAVEWIRE SCREEN (50 mesh — 300			
S	RAINMASTER	FS-150	1 1/2" FLOW SENSOR			
F	RAINMASTER	DX42-UPED-T EV-GROUND-ROD DX-FLOW DX-HW	42 STATION EVOLUTION CONTROLLER WITH F 5/8"x8' COPPER CLAD GROUNDING ROD W FLOW SENSING CIRCUIT BOARD HARDWIRE COMMUNICATION BOARD		LOSURE, PLI	JS THE FOLLOWING:
	RAINMASTER RAINMASTER	EV-CAB-COM EV-CAB-SEN	DIRECT BURIAL COMMUNICATION CABLE (leng DIRECT BURIAL CABLE CONNECTING FLOW SE	·	•	(length as required)
	APCO		COMBINATION AIR VALVE ASSEMBLY (SIZED E	3Y MANUFACT	URER)	

PVC PIPE (MAIN LINE) W/ DUCTILE IRON FITTINGS: ADD MJ AT ALL DIRECTION CHANGES.

PVC PIPE (FUTURE SERVICE LINE) W/ DUCTILE IRON FITTINGS: ADD MJ AT ALL DIRECTION CHANGES.

\*\* ALL SLEEVES TO BE TWICE THE SIZE OF PIPE BEING SLEEVED.

SCH. 40 OR CL. 200

CL. 200 0-RING

CL, 200 O-RING

SCH, 40

ALL MAIN LINE SLEEVES TO BE PARALLELED BY A 2" SLEEVE FOR CONTROLL WIRES. \* ALL P.V.C. PIPE 4" AND LESS TO BE SCH. 40. ALL P.V.C. PIPE LARGER THAN 4" TO BE CL. 200.

PVC PIPE (LATERALS) \*

PVC PIPE (SLEEVES) \* \*\*

SENGINEERING Drw: NCP SALT LAKE CITY - (BO1) 532-2520 Chk: GHG Rvw: JRL of OGDEN - (801) 399-1662 GHG 03/24/06 DFCM REVISIONS Created:05/12/05 | Proj. # 4365 Print Date: 03/24/2006 O GHG 06/03/05 ISSUED FOR BID Copyright © 2003 Bingham Engineering, Inc. Drawing not to be reused in part or in whole without written permission. B |GHG |05/13/05 ISSUED FOR REVIEW Rev. By Date Remarks


WEBER STATE UNIVERSITY

PETERSON PLAZA

IRRIGATION NOTES


PBINGHAM

P:\4365\4365-PROJECT\dwg\4365-IRR-DET.dwg



- (1) POP-UP SPRAY HEAD SEE LEGEND
- (2) FINISH GRADE
- (3) 1" 1 1/2"
- 4 NOTE: ALL SPRAY HEADS TO BE PLACED 2" CLEAR OF ALL HARDSCAPE SURFACES
- (5) SWING PIPE ELL WITH SPIRAL BARB FITTING (TYP.)
- (6) MARLEX STREET ELL
- 7) FLEXIBLE SWING PIPE, 12" MIN. LENGTH (8) PVC SCH 40 SxSxT TEE (OR ELL)
- (9) PVC LATERAL LINE, SIZE AS NOTED
- (1) DEPTH SEE NOTES & TRENCH DETAIL

- 1) POP-UP ROTOR SPRINKLER SEE LEGEND (2) FINISH GRADE
- (3) NOTE: ALL SPRAY HEADS TO BE PLACED 2" CLEAR OF ALL HARDSCAPE SURFACES
- 4 LASCO UNITIZED SWING JOINT OR SPEARS SWING JOINT RISER ASSEMBLY; B" LENGTH; SIZE AS REQUIRED
- (5) PVC SCH 40 SxSxT TEE (OR ELL)
- 6 PVC LATERAL LINE, SIZE AS NOTED
- (7) SWING JOINT ARM INSTALLED AT ANGLE BETWEEN 30 AND 45 DRG. OF LATERAL PIPE
- (8) DEPTH SEE NOTES & TRENCH DETAIL




- 1 10" ROUND GREEN PLASTIC VALVE BOX, CARSON—BROOKS 910 OR EQUAL
- (2) HEIGHT ABOVE FINISH GRADE: 1 1/2" IN TURF AREAS (SODDED); 1" IN TURF AREAS (SEEDED); 2" IN PLANTING AREAS
- (3) QUICK COUPLER VALVE SEE EQUIPMENT SCHEDULE
- (4) BRASS NIPPLE, LENGTH AS REQUIRED
- (5) 6" MIN. DEPTH CLEAN PEA GRAVEL
- (6) REDWOOD OR BRICK BLOCKING, TYPICAL
- 7 12" LASCO UNITIZED SWING JOINT W/ BRASS INSERT STABILIZER ELBOW, OR 12" SPEARS SWING JOINT RISER ASSEMBLY W/ BRASS FEMALE THREAD 90° ELL OUTLET
- (8) DUCTILE IRON SERVICE SADDLE W/ S.S. STRAP (SIDE MOUNTED, SIZE AS REQUIRED)
- PVC MAIN LINE

# 4" POP-UP SPRAY SPRINKLER

# POP-UP GEAR DRIVE ROTOR SPRINKLER

# QUICK COUPLING VALVE



- (1) LATERAL LINE
- (2) PVC SCH. 80 FEMALE ADAPTER
- (3) PVC SCH. 80 UNION
- (4) GREEN PLASTIC VALVE BOX W/ BOLT LOCK (CARSON-BROOKS OR APPROVED EQUAL), SIZE AS REQUIRED
- (5) PROVIDE 12" EXPANSION LOOP AT EACH WIRE CONNECTOR IN BOX
- (6) FINISH GRADE
- (7) WATER TIGHT WIRE CONNECTORS (TYP.)
- 8 ELECTRIC CONTROL VALVE SEE IRRIGATION EQUIPMENT SCHEDULE
- (9) SCH. 80 PVC ELL
- (0) SCH. 80 PVC TOE NIPPLE, LENGTH AS REQ'D
- (1) WIRES TO CONTROLLER, TAPE AND BUNDLE EVERY 10' SEE TRENCH DETAIL
- (12) PVC MAIN LINE
- (3) 4" MIN. DEPTH PEA GRAVEL
- (4) 2" MIN. CLEARANCE REQUIRED
- (15) 2"x4" REDWOOD OR BRICK BLOCKING (TYP.)
- (6) DUCTILE IRON SERVICE TEE, SIZE AS REQ'D
- (18) GATE VALVE (LINE SIZE)

- VALVES < 3' IN SIZE VALVES 3' AND LARGER IN SIZE
- 10" ROUND PLASTIC VALVE BOX, W/ LOCK BOLT, CARSON\_BROOKS 910 OR EQUAL, MARKED "G.V." WITH 2" WHITE LETTERS
- 2 FINISH GRADE
- METAL NIPPLE, 12" MIN. LENGTH, PER BELOW:


  1" 1 1/4" DIA. = GALVANIZED STEEL NIPPLE

  1 1/2" 3" DIA. = DUCTILE IRON NIPPLE
- 4) 2" NIPPLE, DIA. AS REQUIRED
- (5) BRASS UNION (TYP.)
- (6) PVC SCH. 80 FEMALE ADAPTOR (TYP.)
- (7) BELL x FLANGE METAL ADAPTER (TYP.)
- (8) PVC MAINLINE
- (9) 4" MIN. DEPTH CLEAN PEA GRAVEL
- (1) 2"x4" REDWOOD OR BRICK BLOCKING (TYP.)
- (1) DEPTH SEE NOTES
- (2) 2" MINIMUM CLEARANCE REQUIRED
- (3) GATE VALVE (LINE SIZE) SEE EQUIPMENT SCHEDULE

**E** ISOLATION GATE VALVE

VALVES ≥ 2" Ø SHALL HAVE 2" SQUARE OPERATING NUTS. MEGA LUG FITTINGS MAY BE USED AS REQUIRED.

# **CONTROL VALVE ASSEMBLY**



(8) FINISH GRADE

(9) 5/8" X 8' COPPER GROUND ROD

(11) UBGRADE COMPACTED TO 90%

(12) PREFORMED PAD SUPPORT BASE


(13) FILL INSIDE BASE WITH PEA GRAVEL


(14) QUICKPAD FASTENING BRACKET (2)


(10) BRONZE GROUND CLAMP


- (1) CONTROLLER AND CONTROLLER ENCLOSURE - SEE IRRIGATION EQUIPMENT SCHEDULE
- 2 QUICKPAD 3/16" MIN. THCKNESS ALUMINUM POWDER COATED PERFORMED PAD
- PVC SWEEP ELL STATIONS 1-24
- (4) PVC SWEEP ELL STATIONS 25-40 (IF APPLICABLE)
- (5) DIRECT BURIAL CONTROL WIRES TO CONTROL VALVES
- (6) 110-VOLT SERVICE IN CONDUIT

- 1) STEEL INLINE FILTER WITH WEAVEWIRE SCREEN (300 MICRON) SEE PLAN FOR SIZE (2) 3/4" BRASS HOSE BIB AND SADDLE
- (3) FL WAFER BUTTERFLY VALVE—SAME AS LINE SIZE
- (4) FINISH GRADE
- (5) CONCRETE THRUST BLOCKS (TYP.). WRAP PIPES W/ 10 MIL TAPE. CAST AGAINST UNDISTURBED SOIL
- 6 BACKFLOW ENCLOSURE SEE IRRIGATION EQUIPMENT SCHEDULE (FILTER) (INSTALL PER MANUFACTURER'S SPECIFICATIONS)
- (7) FL CAST PIPE—SAME AS LINE SIZE
- (8) FL X PE, SPOOL LENGTH AS REQUIRED (TYP.)
- (9) FL ELL (TYP.)—SAME AS LINE SIZE
- (10) INSTA-FLANGE ADAPTER-SAME AS LINE SIZE (1) 4" THICK CONCRETE PAD (SIZE AS REQUIRED)









Rev. By Date Remarks



**IRRIGATION DETAILS** 


PETERSON PLAZA

PBINGHAM SENGINEERING Drw: RKC SALT LAKE CITY - (BO1) 532-2520 Chk: GHG


P:\4365\4365-PROJECT\dwg\4365-IRR-DET.dwg

OGDEN - (801) 399-1662 1 GHG 03/24/06 DFCM REVISIONS Print Date: 03/24/2006 Created:05/12/05 | Proj. # 4365 0 GHG 06/03/05 ISSUED FOR BID Copyright © 2003 Bingham Engineering, Inc. Drawing not to be reused in part or in whole without written permission. 05/13/05 ISSUED FOR REVIEW

# CONTROLLER & ENCLOSURE



FILTER ENCLOSURE




- (1) 10" ROUND GREEN PLASTIC VALVE BOX, W/ (5) 4" MIN. DEPTH PEA GRAVEL BOLT LOCK, AMATEK OR EQUAL, MARKED "G.V." IN 2" WHITE LETTERS
  - (6) 2x4 REDWOOD OR BRICK BLOCKING
- (2) FINISH GRADE
- (7) WATERPROOF WIRE SPLICES

(3) FLOW SENSOR (4) PVC MAINLINE

(B) SENSOR CABLE TO CONTROLLER


# FLOW SENSOR INSTALLATION



- 1) ADJUSTABLE CURB BOX W/ BOLT LID, CARSON—BROOKS 250 OR EQUAL
- (2) FINISH GRADE
- (3) ADJUST HEIGHT AS REQUIRED
- 4 3/4" BRASS GLOBE VALVE W/ CROSS HANDLE SEE IRRIGATION EQUIPMENT SCHEDULE
- (5) PVC MAINLINE & D. I. SERVICE TEE
- (6) (2)-FIPTxFIPT 90° ELL (2)-3/4" x CLOSE PVC NIPPLE
- (7) 3/4"x6" PVC NIPPLE
- (8) 3/4" 90° STREET ELL
- (9) 3/4" ROCK SUMP 6 C.F. MIN. SIZE (10) FILTER FABRIC COVERING ROCK SUMP
- (1) 3/4" x 6" PVC NIPPLE


1) ALL PVC NIPPLES TO BE SCHEDULE 80. 2) PROVIDE VALVE KEY TO OWNER

# **D** MANUAL DRAIN VALVE



- 1) FINISH GRADE
- ② JUMBO PLASTIC VALVE BOX W/ LOCK BOLT, AND EXTENSION. CARSON—BROOKS OR EQUAL.
- 3 COMBINATION AIR VALVE SEE IRRIGATION EQUIPMENT SCHEDULE (INSTALL PER MANUFAC, SPECS.)
- (4) BRASS BALL VALVE, SIZE AS REQUIRED
- (5) 90° BRASS OR GALV. ELL (TYP.)
- (6) 2" MIN. CLEARANCE REQUIRED
- 7 BRASS OR GALV. NIPPLE, LENGTH AS REQUIRED (TYP.)
- (8) 6" MIN. DEPTH WASHED PEA GRAVEL
- (9) MAIN LINE
- (10) MJ OR SS DOUBLE STRAPPED SERVICE SADDLE
- HEIGHT AT FINISHED GRADE OR AT 2" IN PLANTING BEDS
- SUPPORT BLOCK FOR VALVE RECOMMENDED


# **COMBINATION AIR VALVE ASSEMBLY**



#### SUGGESTED SPECIFICATIONS:


ALL 4" AND LARGER FITTINGS, AND 3", 2 1/2", & 2" FULL SIZE TEES SHALL BE MANUFACTURED OF DUCTILE IRON, GRADE 65-45-12 IN ACCORDANCE WITH ASTM A-536. FITTINGS SHALL BAVE DEEP BELL PUSH—ON JOINTS WITH GASKETS MEETING ASTM F—477.
FITTINGS SHALL BE "HARCO DEEP BELL" AS MANUFACTURED BY THE HARRINGTON
CORPORATION OF LYNCHBURG, VA. TRANSITION GASKETS ARE NOT ALLOWED.

# **B** DUCTILE IRON FITTINGS



- 1 BACKFILL MATERIAL SEE NOTES, COMPACT TO 90% MIN.
- (2) ADJACENT HARD SURFACE
- (3) NON-PRESSURE LATERAL LINE
- (4) PRESSURE MAIN LINE
- 5 DIRECT BURIAL, LOW VOLTAGE CONTROL WIRES; TAPE AND BUNDLE AT 10 FT, Q,C.
- (6) BEDDING MATERIAL SEE NOTES
- (7) PIPE DEPTHS SEE NOTES
- NOTE: SEE SLEEVING DETAIL FOR TRENCHING IN PAVED AREAS.

# TRENCH DETAIL



← DIRECTION OF THRUST (TYP.) INSTALL THRUST BLOCKS ON ALL 3" FITTINGS AND VALVES


# THRUST BLOCK DETAILS

#### THRUST BLOCKING INSTRUCTIONS

- PROVIDE THRUST BLOCKS AT ALL CHANGES IN SIZE OR DIRECTION. BENDS, REDUCERS, PLUGS, AND THE OPPOSITE SIDE OF TEE BRANCHES ALL REQUIRE THRUST BLOCKS.
   THE SIZES OF THE BLOCKS ARE DETERMINED BY THE WORKING PRESSURE, THE SIZE AND TYPE OF FITTING, AND SOIL CONDITIONS AT THE JOB SITE. TO CALCULATE THE AREA OF CONTACT WITH THE SOIL,
- FOLLOW THESE STEPS:

  CALCULATE THE THRUST BY SELECTING THRUST/100 BY SIZE AND TYPE OF FITTING FROM
  TABLE 1 AND MULTIPLYING THRUST/100 BY SYSTEM PRESSURE DIVIDED BY 100.

  DIVIDE THE TOTAL THRUST BY BEARING CAPACITY OF THE SOIL IN EXCAVATION (FROM TABLE 2) TO
  DETERMINE THE AREA IN SQUARE FEET OF THRUST BLOCK REQUIRED TO BE IN CONTACT WITH THE UNDISTURBED SOIL.






TABLE 1 - THRUST/100 90 45 22.5 Plugs Bends Bends Bends 
 363
 513
 259
 141

 531
 751
 379
 207

 788
 1,114
 562
 307

 1,302
 1,841
 928
 508

 2,822
 3,990
 2,012
 1,101

 2,822
 3,990
 2,012
 1,201
 2 1/2

FOR REDUCERS, SUBTRACT SMALL OPENING PLUG THRUST FROM LARGE OPENING PLUG THRUST TO CALCULATE THRUST/100.


4,783 6,763 3,410 1,865 7,430 10,506 5,297 2,898 10,452 14,778 7,452 4,076

TABLE 2 - SAFE BEARING LOAD

SOIL TYPE	LBS PER	SQ FT*
Soft Clay		1,000
Sand		2,000
Sand & Gravel		3,000
Sand & Gravel cemented	w/Clay	4,000
Hard Pan		10.000

\*HARCO ASSUMES NO RESPONSIBILITY FOR THE ABOVE BEARING LOAD DATA. THE ENGINEER IS RESPONSIBLE FOR DETERMINING SAFE BEARING LOADS, AND WHEN DOUBT EXISTS, SOIL BEARING TESTS SHOULD BE SPECIFIED.
THE BEARING LOADS GIVEN ARE FOR HORIZONTAL THRUSTS
WHEN DEPTH OF COVER EXCEEDS 2 FEET.

# THRUST BLOCKING INSTRUCTIONS



- (1) HARDSCAPE SURFACE SEE CIVIL PLANS
- (2) BACKFILL MATERIAL SEE NOTES
- (3) LATERAL LINE W/SLEEVE.
- (4) PRESSURE MAIN LINE SLEEVE
- (5) CONTROL WIRE SLEEVE (SAME SIZE AS MAIN LINE SLEEVE)
- (6) BEDDING MATERIAL SEE NOTES
- Ø MINIMUM COVER: 12" UNDER WALKS 18" UNDER STREETS

- SLEEVES 4" AND SMALLER USE PVC SCH. 40 PIPE.
  SLEEVES >4" USE PVC CLASS 200 PIPE
  ALL SLEEVES SHALL BE TWO (2) TIMES LARGER
- THAN DIAMETER OF PIPE TO BE SLEEVED.

  INSTALL SLEEVES AT A DEPTH TO AVOID CONFLICT WITH OTHER UTILITIES AND MAINS.







### WEBER STATE UNIVERSITY PETERSON PLAZA


**IRRIGATION DETAILS** 


BINGHAM
Den: RKC
Drw: RKC
Chk: GHG
Chk: GHG
Den: RKC
Drw: RKC
Chk: GHG
Den: RKC
Drw: RKC
Chk: GHG
Den: RKC
Den: RKC
Drw: RKC
Drw:


				_  SALT LAKE CITY - (BO1) 532-2520		- IDI		. –
1	GHG	03/24/06	DFCM REVISIONS	OGDEN - (801) 399-1662		Rvw: <u>JRL</u>	of	6
0	GHG	06/03/05	ISSUED FOR BID	Print Date: 03/24/2006	Created:0	5/12/05	Proj.	# 4365
В	GHG	05/13/05	ISSUED FOR REVIEW	Copyright © 2003 Bingham Engineer or in whole without written permiss		rawing not to	be rev	u <b>se</b> d in part
Rev.	Ву	Date	Remarks	P:\4365\4365-PROJECT\dwg\436	55-IRR-DE	T.dwg		RK












# PETERSON PLAZA PLANT SCHEDULE

<u> </u>	QTY.	BOTANICAL NAME	COMMON NAME	SIZE	REMARKS
<u>TREES</u> ACF	1	Aesculus x carnea 'Ft. McNair'	Ft. McNair Horsechestnut	2" Cal.	Well Formed Speciman
AH	2	Aesculus hippocastanum	Horsechestnut	2" Cal.	Well Formed Specimar
ARS	9	Acer rubrum 'Red Sunset'	Red Sunset Red Maple	2" Cal.	Well Matched. '
ASG	1	Acer saccharum 'Green Mountain'	Green Mountain Sugar Maple	2" Cal.	Well Formed Specimar
BJ	6	Betula jacquemontii	White Birch	2" Cal.	Well Formed Speciman
CCE	1	Cercis canadensis	Eastern Redbud	2" Cal.	Well Formed Speciman
CCI	1	Crataegus crus—galli 'inermis'	Thornless Cockspur Hawthorn	2" Cal.	W II 5 1 0 1
CLU CPW	2	Cladrastis kentukea/lutea Crataegus phaenopyrum 'Washington'	Yellowwood Washington Hawthorn	2" Cal. 2" Cal.	Well Formed Specimar
PE	5	Pinus edulis	Pinion Pine	6' Height	
PYA	7	Prunus x yedoensis 'Akebono'	Akebono Cherry	2" Cal.	Well Matched.
RPP	1	Robinia pseudoacacia 'Purple Crown'	Purple Crown Locust	2" Cal.	Well Formed Specimar
UF	10	Ulmus x 'Frontier'	Frontier Elm	2" Cal.	Well Matched.
SHRUBS				F 0 1	
AA ACG	8	Amelanchier alnifolia	Saskatoon Serviceberry	5 Gal.	
ACG AME	2 5	Abies concolor glauca Aronia melanocarpa elata Black	Blue Cloak Fir Black Chokeberry	5 Gal. 5 Gal <i>.</i>	
ANL	32	Azalea 'Northern Lights'	Northern Lights Azalea	5 Gal.	
BB	11	Buddleia 'Bicolor'	Butterfly Bush	5 Gal.	
CAR	8	Clethra alnifolia 'Ruby Spice'	Ruby Spice Summersweet	5 Gal.	
CLU	16	Cotoneaster lucidis	Peking Cotoneaster	5 Gal.	
CSI COV	6	Cornus sericea 'Isanti'	Isanti Red Twig Dogwaod	5 Gal.	
CSK CSR	33 40	Cornus sericea 'Kelseyi' Cotoneaster salicifolius repens	Kelseyi Dogwood Willowleaf Cotoneaster	5 Gal. 5 Gal.	
۱۱ ت	40	'Emerald Carpet'	Willowieur Cotolleaster	J Gui.	
EAC	10	Euonymus alatus compacta	Dwarf Burning Bush	5 Gal.	
FSG	6	Forsythia 'Spring Glory'	Forsythia	5 Gal.	
GLW	29	Genista lydia	Lydia Woodwaxen Broom	5 Gal.	
HD	5	Holodiscus discolor	Ocean Spray	5 Gal.	
JHB	89	Juniperus horizontalis 'Blue Chip'	Blue Chip Juniper	5 Gal.	
JCS	11	Juniperus chinensis 'Sea Green'	Sea Green Juniper	5 Gal.	
JSC	39	Juniperus sabina 'Calgary Carpet'	Calgary Carpet Juniper	5 Gal.	
KJP	18	Kerria japonia 'plentiflora'	Japanese Kerria	5 Gal.	
MAC PFA	95 36	Mahonia aquefolium 'Compacta' Potentilla fruticosa 'Abbottswood'	Dwarf Oregon Grape Abbottswood Shrubby Cinquefoil	5 Gal. 2 Gal.	
PFG	40	Potentilla fruticosa 'Goldstar'	Goldstar Shrubby Cinquefoil	2 Gal.	
PLS	15	Prunus laurocerasus 'schipkaensis'	Shipka English Laurel	5 Gal.	
PMM	56	Pinus mugo mugus 'Pumilio'	Shrubby Swiss Mountain Pine	5 Gal.	
RAG	58	Rhus aromatica 'Grow Low'	Grow Low Fragrant Sumac	5 Gal.	
RGC	12	Rhus glabra 'cismontana'	Dwarf Smooth Sumac	5 Gal.	
RPJ	17	Rhadodendron PJM	PJM Rhododendron	5 Gal.	
SA SAR	22 5	Symphoricarpos alba Shepherdia argentea	Common Snowberry Silver Buffaloberry	5 Gal. 5 Gal.	
SAR S0	20	Symphoricarpos oreophilus	Mountain Snowberry	5 Gal. 5 Gal.	
TBR	70	Taxus baccata repandens	Dwarf Spreading Yew	5 Gal.	
<u>PERENI</u>		_			
AM		Achillea 'Moonshine'	Moonshine Yarrow	1 Gal.	
AMM	52 54	Aquilegia 'Music Mix'	Columbine	1 Gal.	
CAA	54 50	Calamagrostis x acutifolia 'Avalanche'	Avalanche Feather Grass	1 Gal.	
CFS CSD	50 69	Coreopsis 'Flying Saucers' Coreopsis 'Sweet Dreams'	Flying Saucers Tickseed Sweet Dreams Tickseed	1 Gal. 1 Gal.	
FOG	56	Festuca ovina glauca 'Elijah Blue'	Elijah Blue Fescue Grass	1 Gal.	



- 1 ROOTBALL
- 2 CROWN 1"-2" ABOVE FINISH GRADE
- 3 FINISH GRADE
- 4 FINISH GRADE AT SLOPE (WHERE OCCURS)

- (5) 3x ROOTBALL DIA. MIN. (UNLESS TREE DETAIL SHOWS OTHERWISE)
- 6 BACKFILL MIX (SEE NOTES)
- 8) TOP OF PAVING
- 9 3" HIGH WATERING BASIN
- 10 UNDISTURBED OR 90% COMPACTED SOIL
- 1) 3" LAYER SHREDDED BARK MULCH AROUND EACH TREE IN 3' RADIUS CIRCLE



SYM.	BOTANICAL NAME	COMMON NAME	(QTY) SIZE	REMARKS
GROUND CO	<u>vers</u>			
	Lysimachia nummalaria	Creeping Jenny	(11) F/36	Plant @ 12" spacing (±387 SF)
	Mahonia repens	Creeping Oregon Grape	(30) F/36	Plant @ 18" spacing (±1,606 SF)
	Pachistima canabyi	Dwarf Mountain Lover	(9) F/36	Plant @ 18" spacing (±446 SF)
	Vinca minor 'Bowles'	Dwarf Periwinkle	(162) F/36	Plant @ 12" spacing (±5,850 SF)
	Festuca arundinacea 'Triathalown'	Triathalawn Tall Fescue	2,035 SF	Hydroseed
ψ ψ Ψ	Grasses/Wildflower Mix (See Below)		15,058 SF	Hydroseed

# GRASSES/WILDFLOWER MIX

BOTANICAL NAME	COMMON NAME	PERCENT
GRASSES		
Elymus lanceolatus ssp. dasystachyum	Thickspike Wheatgrass	20.0%
Festuca ovina MX-86	Sheep Fescue	7.5%
Poa sandbergii	Sandberg Bluegrass	5.0%
Bouteloua gracilis	Blue Grama	5.0%
<u>WILDFLOWERS</u>		
Gaillardia aristata	Blanket Flower	22.5%
Eschscholzia californica	California Poppy	15.0%
Linum lewisii	Blue Flax	15.0%
Coreopsis lanceolata	Lance-leaved Coreopsis	<u>10.0%</u>
SEED MIXES AVAILABLE THROUGH:		100.0% HYDROSEEDED @ 1 LB/1,0

SEED MIXES AVAILABLE THROUGH: GRANITE SEED
1597 WEST 2100 NORTH
LEHI, UTAH 84043

(801)768-4422 LEHI (801)531-1456 SALT LAKE (801)768-3967 FAX

WEBER STATE UNIVERSITY PETERSON PLAZA

PLANTING SCHEDULE

	Rev.	Ву	Date	Remarks	P:\4365\4365-PROJECT\dwg\436	65-PLANT-	DET.dwg			RKC
ı	В	GHG	05/13/05	ISSUED FOR REVIEW	Copyright © 2003 Bingham Engineering, Inc. Drawing not to be reused in p or in whole without written permission.				used in po	ırt
	0	GHG	06/03/05	ISSUED FOR BID	Print Date: 03/24/2006	Created:0	1/01/01	Proj.	#	
	1	GHG	03/24/06	DFCM REVISIONS	OGDEN - (801) 999-	1882	Rvw:	of	7	

### PLANTING NOTES

- 1. THE PLANTING PLAN IS DIAGRAMMATIC, AND ALL PLANT LOCATIONS ARE APPROXIMATE,
- A. PLANT SYMBOLS TAKE PRECEDENCE OVER PLANT QUANTITIES SPECIFIED ON B. CONTRACTOR SHALL VERIFY PLANT QUANTITIES AND NOTIFY THE LANDSCAPE
- ARCHITECT OF ANY DISCREPANCIES BETWEEN QUANTITIES AND SYMBOLS SHOWN. 2. PRIOR TO PLANTING, THE IRRIGATION SYSTEM SHALL BE FULLY OPERATIONAL
- 3. LANDSCAPE CONTRACTOR SHALL APPLY A CONTACT HERBICIDE TO ALL PLANTING AREAS WHERE WEEDS OR UNDESIRABLE VEGETATION ARE PRESENT PER MANUFACTURERS SPECIFICATIONS A MINIMUM OF TEN (10) DAYS PRIOR TO COMMENCEMENT OF ANY PLANTING OR IRRIGATION WORK. WEEDS SHALL BE ALLOWED TO COMPLETELY DIE BACK, INCLUDING THE ROOTS, BEFORE PROCEEDING WITH WORK. DEAD WEEDS SHALL BE REMOVED FROM THE SITE.
- 4. ALL PLANTING AREAS SHALL RECEIVE A MINIMUM OF FOUR (4) INCHES OF IMPORTED TOPSDIL IN LAWN AREAS AND TWELVE (12) INCHES IN PLANTING BEDS. ALL TOPSOIL USED ON THIS PROJECT SHALL MEET THE FOLLOWING CRITERIA: A. pH: 5.5 — 8.0
- B. EC (ELECTRICAL CONDUCTIVITY): <2.0 mmhos PER CENTIMETER
- C. SAR (SODIUM ABSORPTION RATIO); <3.0
- D. %OM (PERCENT ORGANIC MATTER): >1%
- E. TEXTURE (PARTICLE SIZE PER USDA SOIL CLASSIFICATION): SAND: <70%

AND ALL PLANTING AREAS SHALL BE THOROUGHLY MOISTENED.

- CLAY: <30%
- SILT: = BALANCE
- F. STONE FRAGMENTS (GRAVELS OR ANY SOIL PARTICLE GREATER THAN 2 MM IN SIZE): <5% (BY VOLUME)
- IN ADDITION, THE SOIL SHALL BE FERTILE, FRIABLE, NATURAL LOAM AND SHALL BE CAPABLE OF SUSTAINING VIGOROUS PLANT GROWTH. IT SHALL BE FREE OF STONES, LUMPS, CLODS OF HARD EARTH, PLANTS OR THEIR ROOTS, STICKS AND OTHER EXTRANEOUS MATTER. THE SOIL SHALL CONTAIN NO NOXIOUS WEEDS NOR THEIR SEEDS. IT SHALL NOT BE USED FOR PLANTING OPERATIONS WHILE IN A FROZEN OR MUDDY CONDITION.
- 5. LANDSCAPE CONTRACTOR SHALL OBTAIN A SOIL ANALYSIS FROM ANY AUTHORIZED SOIL TESTING AGENCY OF ANY EXISTING STOCKPILED OR IMPORTED TOP SOIL TO BE USED ON THE PROJECT TO VERIFY ITS CONFORMANCE TO THE ABOVE SPECIFIED CRITERIA. TEST RESULTS SHALL INCLUDE HORTICULTURAL RECOMMENDATIONS. SOIL SAMPLES SHALL BE OBTAINED PER TESTING AGENCY DIRECTIONS. ALLOW TEN (10) WORKING DAYS TO OBTAIN RESULTS OF SOIL TESTS. COSTS FOR SUCH TESTING SHALL BE THE RESPONSIBILITY OF THE LANDSCAPE CONTRACTOR.
- 6. PRIOR TO DELIVERY OF IMPORTED TOPSOIL TO THE SITE, THE LANDSCAPE CONTRACTOR SHALL PROVIDE TO THE OWNER (OR OWNER'S AUTHORIZED REPRESENTATIVE) THE NAME AND LOCATION OF THE TOPSOIL SOURCE, ALONG WITH THE CERTIFIED SOIL ANALYSIS OF THE TOPSOIL TO BE USED. THE ANALYSIS SHALL VERIFY THAT THE PROPOSED TOPSOIL MEETS THE ABOVE OUTLINED CRITERIA, AND IS CAPABLE OF SUPPORTING HEALTHY PLANT GROWTH.
- 7. THE FOLLOWING PROCEDURES SHALL BE FOLLOWED IN PLACING ALL TOPSOIL A. ALL AREAS TO BE PLANTED WHICH HAVE A SLOPE OF LESS THAN 10% SHALL BE CROSS-RIPPED TO A DEPTH OF FOUR (4) TO SIX (6) INCHES.
- B. SUBGRADE MATERIAL SHALL BE ROUGH GRADED TO PLUS OR MINUS 0.1 FEET OF A FINAL ROUGH GRADE WHICH WILL ALLOW THE CONTRACTOR TO ACHIEVE FINAL FINISH GRADE THROUGH THE INSTALLATION OF IMPORTED TOPSOIL C. SCARIFY SURFACE OF SUBGRADE TO A TWO (2) INCH DEPTH TO PROVIDE TRANSITION ZONE BETWEEN SUBGRADE AND TOPSOIL. PLACE TOPSOIL ON SUBGRADE AND FINE GRADE TO FINAL FINISH GRADE AND TOPSOIL DEPTHS AS INDICATED ON THE DRAWINGS AND IN THESE NOTES.
- D. THE FOLLOWING AMENDMENTS SHALL BE APPLIED TO THE SURFACE AND RAKED INTO THE SOIL DURING FINE GRADING PROCEDURES:
- 1. 16-16-16 SLOW RELEASE FERTILIZER CONTAINING TRACE ELEMENTS AT A RATE OF 1 POUND OF NITROGEN PER 1000 SF (6.25 POUNDS OF FERTILIZER).
- 8. LANDSCAPE CONTRACTOR SHALL MAINTAIN A MINIMUM 2% DRAINAGE AWAY FROM ALL BUILDINGS, STRUCTURES, AND WALLS. FINISHED GRADES SHALL BE SMOOTHED TO ELIMINATE PUDDLING OR STANDING WATER.
- 9. ALL FINISHED GRADES SHALL BE APPROVED BY THE OWNER/OWNER'S AUTHORIZED REPRESENTATIVE PRIOR TO INSTALLATION OF ANY PLANT MATERIALS.
- 10. CONTRACTOR SHALL HAVE THE LANDSCAPE ARCHITECT APPROVE PLANT MATERIAL SIZE AND QUALITY PRIOR TO INSTALLATION. ANY PLANTS WHICH ARE NOT TRUE TO FORM, APPEAR STRESSED OR UNHEALTHY, INFESTED WITH PESTS, OR UNDERSIZED FOR THEIR CONTAINERS SHALL BE REJECTED.
- 11. PLANT MATERIAL SHALL NOT BE ROOT BOUND. FIVE (5) GALLON PLANTS AND LARGER SHALL HAVE BEEN GROWN IN CONTAINERS FOR A MINIMUM OF SIX (6) MONTHS UP TO A MAXIMUM OF TWO (2) YEARS. PLANTS SHALL EXHIBIT HEALTHY GROWTH AND BE FREE OF DISEASES AND PESTS.
- 12. CONTRACTOR SHALL SPOT THE LOCATIONS OF ALL PLANTS FOR APPROVAL BY THE LANDSCAPE ARCHITECT PRIOR TO INSTALLATION.
- 13. PLANTS SHALL NOT BE PLACED WITHIN TWELVE (12) INCHES OF SPRINKLER
- 14. PLANT BACKFILL MIX SHALL BE 50% NATIVE SITE SDIL AND 50% TOPSOIL

UNLESS OTHERWISE SPECIFIED.

15. TYPAR GEOTEXTILE FABRIC SHALL BE PLACED IN ALL SHRUB BEDS (EXCLUDING UNDER PERENNIAL PLANTS (DAYLILY, VINCA, CONE FLOWER, SHASTA DAISY, BLANKET FLOWER, AND HOSTA) AND UNDER PEA GRAVEL. FABRIC SHALL BE PLACED DIRECTLY ON THE TOP OF THE TOPSOIL AND SECURELY ANCHORED PER MANUFACTURER'S RECOMMENDATIONS. ALL CORNERS AND SEAMS SHALL BE TUCKED INTO TOPSOIL AND SECURLY ANCHORED. IRRIGATION HEADES MAY PENETRATE THE FABRIC AS REQUIRED TO FUNCTION PROPERLY. COVER WITH A THREE (3) INCH LAYER OF SHREDDED BARK MULCH. HOLES IN THE FABRIC SHALL ONLY BE ALLOWED FOR PASSAGE OF IRRIGATION MATERIALS AND PLANTS. NO FABRIC SHALL BE VISIBLE IN ANY LOCATION.

- 16. PLANTING PROCEDURES FOR ALL PLANT MATERIALS, ESPECIALLY TREES, SHALL BE AS FOLLOWS:
- A. DIG PLANTING HOLE THREE (3) TIMES THE WIDTH OF THE ROOT BALL, AND ONE TO TWO (1-2) INCHES SHALLOWER THAN THE ROOT BALL DEPTH. SIDES OF HOLE SHOULD BE ROUGHENED AND NOT SMOOTH OR SCULPTED.
- B. FOR CONTAINER PLANTS, REMOVE CONTAINER AND PLACE ROOT BALL IN CENTER OF HOLE, WITH ROOT BALL RESTING ON UNDISTURBED SOIL. ROOT CROWN OR COLLAR SHALL BE AT OR JUST ABOVE FINISHED GRADE.
- C. FOR BALLED AND BURLAPPED PLANTS, PLACE ROOT BALL IN CENTER OF HOLE AND RESTING ON UNDISTURBED GROUND. CUT AND REMOVE WIRE BASKET AND BURLAP OR OTHER WRAPPING MATERIAL FROM ROOT BALL. THIS MAY BE DONE WITH ROOT BALL IN HOLE. BURLAP OR WIRE PIECES UNDERNEATH THE ROOT BALL MAY BE LEFT IF THEY CANNOT BE REMOVED. DO NOT FOLD BURLAP OVER, BUT CUT AWAY AS MUCH AS POSSIBLE WITHOUT DISTURBING ROOT BALL. BACKFILL BOTTOM THIRD (1/3) OF HOLE AS WIRE AND BURLAP ARE REMOVED. D. BACKFILL WITH SPECIFIED SOIL MIX, FILLING HOLE TO TWO THIRDS (2/3)
- E. THOROUGHLY WATER PLANT, THEN COMPLETE BACKFILLING THE HOLE. FORM A WATERING BASIN AROUND THE PLANT AND THOROUGHLY WATER AGAIN. F. MONITOR ALL PLANTS TO INSURE THAT NO SETTLING OCCURS.
- 17. AFTER PLANTING, THE FOLLOWING OPERATIONS SHALL BE PERFORMED:
- A. STAKE AND MULCH ALL TREES PER INSTALLATION DETAILS. B. REMOVE NURSERY STAKES AND TIES FROM ALL CONTAINER STOCK. MAINTAIN SIDE GROWTH ON ALL TREES. PRUNE AND REMOVE ANY DEAD, DAMAGED OR BROKEN BRANCHES.
- 18. ALL PLANTERS ARE TO RECEIVE A THREE (3) INCH TOP DRESSING OF WOOD FIBER MULCH. JUST PRIOR TO PLACEMENT OF MULCH, TREAT AREAS WITH PRE-EMERGENT HERBICIDE ACCORDING TO MANUFACTURERS RECOMMENDATIONS.
- 19. THE LANDSCAPE CONTRACTOR SHALL LEAVE SITE IN A CLEAN CONDITION, REMOVING ALL UNUSED MATERIAL, TRASH AND TOOLS.
- 20. AT SUBSTANTIAL COMPLETION OF ALL WORK OUTLINED IN THESE PLANS, THE LANDSCAPE CONTRACTOR SHALL CONTACT OWNER AND ARRANGE FOR A WALK THROUGH. SUBSTANTIAL COMPLETION SHALL BE DEFINED AS COMPLETION OF ALL WORK OUTLINED IN THE PLANS AND SPECIFICATINS WITH THE EXCEPTION OF FINAL CLEAN UP AND DEMOBILIZATION. WORK MUST BE FULLY COMPLETED ACCORDING TO ALL PLANS, NOTES, AND SPECIFICATIONS AND EXHIBIT PROFESSIONAL WORKMANSHIP, A MAINTENANCE PERIOD WILL BEGIN ON THE DATE OF ACCEPTANCE OF SUBSTANTIAL COMPLETION BY OWNER.
- 21. LANDSCAPE CONTRACTOR SHALL MAINTAIN ALL PLANTINGS UNTIL TURF IS FULLY ESTABLISHED. TURF SHALL BE CONSIDERED FULLY ESTABLISHED WHEN GRASS STANDS COME IN UNIFORM AND THICK, WITH NO BARE OR THIN SPOTS, AND ROOTS HAVE BEGUN TO SPREAD AND KNIT TOGETHER. NO WEEDS SHALL BE ALLOWED IN THE GRASS. THIS SHALL BE A MINIMUM PERIOD OF SIXTY (60) DAYS. THE MAINTENANCE WORK REQUIRED SHALL INCLUDE BUT NOT BE LIMITED TO THE FOLLOWING:
- A, DAILY WATERING OF ALL PLANT MATERIAL. B. WEEDING AND REMOVAL OF ALL WEEDS FROM GROUND COVER AND
- PLANTING AREAS. C. REPLACEMENT OF ANY DEAD, DYING, OR DAMAGED TREES, SHRUBS OR
- GROUNDCOVER. D. FILLING AND REPLANTING OF ANY LOW AREAS WHICH MAY CAUSE STANDING
- E. ADJUSTING OF SPRINKLER HEAD HEIGHTS AND WATERING PATTERNS F, FILLING AND RECOMPACTION OF ERODED AREAS, ALONG WITH ANY REQUIRED
- RE-SEEDING AND/OR RE-PLANTING. G. GRASS SHALL BE MOWED WHEN BLADES REACH THREE (3) INCHES TALL NO MORE THAN ONE THIRD (1/3) OF THE BLADE SHALL BE REMOVED PER
- CUTTING. CUTTING FREQUENCY SHALL BE ONCE EVERY FIVE (5) TO SEVEN (7)
- H. WEEKLY REMOVAL OF ALL TRASH, LITTER, CLIPPINGS AND ALL FOREIGN DEBRIS.
- I. AT 30 DAYS AFTER PLANTING, A BALANCED FERTILIZER 16-16-16 SHALL BE APPLIED TO GRASS AREAS AT A RATE OF ONE HALF (1/2) POUND OF NITROGEN PER 1000 SQUARE FEET,
- J. AT INTERVALS OF THIRTY (30) DAYS AFTER FIRST APPLICATION OF FERTILIZER TO GRASS, APPLY A BALANCED FERTILIZER 16-16-16 AT A RATE OF ONE HALF (%) POUND OF NITROGEN PER 1000 SQUARE FEET UNTIL GRASS IS ESTABLISHED.
- 22. PRIOR TO END OF MAINTENANCE PERIOD, LANDSCAPE CONTRACTOR SHALL CONTACT OWNER AND ARRANGE FOR A FINAL WALK THROUGH BEFORE FINAL ACCEPTANCE, OWNER MUST ACCEPT ALL MAINTAINED AREAS IN WRITING PRIOR TO END OF MAINTENANCE PERIOD.
- 23. LANDSCAPE CONTRACTOR SHALL GUARANTEE PLANT MATERIALS AS FOLLOWS: A, ALL SHRUBS AND GROUND COVERS SHALL BE GUARANTEED BY THE CONTRACTOR AS TO GROWTH AND HEALTH FOR A PERIOD OF SIXTY (60) DAYS AFTER COMPLETION OF THE MAINTENANCE PERIOD AND FINAL ACCEPTANCE. ALL TREES SHALL BE GUARANTEED BY THE CONTRACTOR TO LIVE AND GROW IN AN ACCEPTABLE UPRIGHT POSITION FOR A PERIOD OF ONE (1) YEAR AFTER COMPLETION OF THE SPECIFIED MAINTENANCE PERIOD AND FINAL ACCEPTANCE.
- B. THE ONLY CONDITIONS WHICH RELIEVE THE CONTRACTOR FROM THE GUARANTEE OF PLANT MATERIALS AS DESCRIBED ABOVE ARE THOSE WHICH CAN BE SHOWN ARE A DIRECT RESULT OF IMPROPER CARE OR WATERING BY THE OWNER AFTER THE MAINITENANCE PERIOD AND DURING THE GUARANTEE PERIOD.
- C. THE CONTRACTOR, WITHIN FIFTEEN (15) DAYS AFTER RECEIVING WRITTEN NOTIFICATION BY THE ARCHITECT, SHALL REMOVE AND REPLACE ALL GUARANTEED PLANT MATERIALS WHICH FAIL TO MEET THE REQUIREMENTS OF THE GUARANTEE. REPLACEMENT SHALL BE MADE WITH PLANT MATERIALS AS INDICATED OR SPECIFIED ON THE ORIGINAL PLANS, AND ALL SUCH REPLACEMENT MATERIALS SHALL BE GUARANTEED AS SPECIFIED FOR THE ORIGINAL MATERIALS.


#### SOD INSTALLATION

- 1, SOD SHALL MEET THE FOLLOWING REQUIREMENTS: A. SOD SHALL BE OBTAINED FROM APPROVED SOURCES. THE SOD SHALL HAVE BEEN MOWED REGULARLY AND CAREFULLY MAINTAINED FROM PLANTING TO
- B. THE SOD SHALL BE FREE OF GRASSY AND BROAD LEAF WEEDS AND BARE OR BURNED SPOTS, CLEAN AND STRONGLY ROOTED, AND OF THE VARIETIES
- NOTED ON THE PLANS AND NOTES, C. THE SOD SHALL BE CUT USING APPROVED METHODS, IN PIECES NOT EXCEEDING 1 SQUARE YARD, WITH MINIMUM ONE HALF (1/2) INCH AND MAXIMUM
- ONE (1) INCH THICKNESS. D. LÁNDSCAPE CONTRACTOR SHALL NOTIFY THE LANDSCAPE ARCHITECT OF THE SOURCE OF THE SOD PRIOR TO PLACEMENT. THE SOD SHALL BE STRIPPED AND DELIVERED TO THE SITE NOT MORE THAN 24 HOURS PRIOR TO LAYING. THE SOD SHALL BE MAINTAINED AS MOIST AND IN GOOD CONDITION TO ENCOURAGE
- E. THE FOLLOWING PROCEDURE SHALL BE FOLLOWED IN INSTALLING SOD: 1. LAY THE SOD ON SMOOTH, MOIST TOPSOIL, WORKING OFF PLANKS IF REQUIRED.
- 2. RAKE TOPSOIL TO LOOSEN AND LEVEL PRIOR TO PLACING EACH COURSE OF SOD.
- 3. LAY STRIPS PERPENDICULAR TO DIRECTION OF SLOPE. STRIPS SHALL BE PARALLEL TO EACH OTHER, THEIR END SEAMS STAGGERED. SOD SHALL NOT BE STRETCHED OR OVERLAPPED AND ALL JOINTS SHALL BE BUTTED TIGHT. 4. ROLL SDD IMMEDIATELY AFTER PLACING AND THOROUGHLY WATER WITH A FINE SPRAY TO A DEPTH SUFFICIENT THAT THE UNDERSIDE OF THE NEW SOD AND SDIL IMMEDIATELY BELOW THE SOD ARE THROUGHLY WET.
- 5. ON SLOPES 3 HORIZONTAL TO 1 VERTICAL AND STEEPER, LAY SOD PERPENDICULAR TO SLOPE AND SECURE EVERY ROW WITH WOODEN PEGS AT 2 FEET MAXIMUM ON CENTER. DRIVE PEGS FLUSH WITH SOIL PORTION OF SOD.

#### HYDROSEED NOTES

IMMEDIATE GROWTH.

- 1. HYDROSEED WILL CONFORM TO THE FOLLOWING:
- A. WOOD FIBER MULCH SHALL BE VIRGIN WOOD FIBER, FREE OF GROWTH OR GERMINATION INHIBITING SUBSTANCES. MULCH SHALL BE AIR DRIED WITH NO MORE THAN 15% MOISTURE BY WEIGHT. TOTAL ORGANIC WEIGHT SHALL BE A MINIMUM OF 98%. INORGANIC ASH CONTENT SHALL BE 0.7+/-0.2 PERCENT WATER HOLDING CAPACITY SHALL BE 1000G/100G (OVEN DRIED WEIGHT BASIS). PH RANGE SHALL BE 4.0-6.0. FIBER LENGTH SHALL MEET THE FOLLOWING:
- 30% MINIMUM SHALL BE AT LEAST 0.15 INCHES IN LENGTH OR LONGER 50% MINIMUM SHALL BE RETAINED ON THE 28 MESH SCREEN.
- B. SEE PLANT SCHEDULE FOR SEED MIX. C. PROVIDE WRITTEN CERTIFICATION THAT SEED CONFORMS TO UTAH SEED LAW IN COMPLIANCE WITH UTAH STATE DEPT. OF AGRICULTURE REGULATIONS.
- D. ORGANIC TACKIFIER SHALL BE "M-BINDER" AS MANUFACTURED BY ECOLOGY CONTROLS, "TYPE-M" AS MANUFACTURED BY AGRO TACK, "STA WET" AS MANUFACTURED BY POLYSORB, INC. OR APPROVED EQUAL.
- E. APPLICATION RATE PER 1000 SQUARE FEET IS AS FOLLOWS:
- . 35 POUNDS OF WOOD FIBER MULCH, 2. SEE PLANT LIST FOR POUNDS OF SEED MIX PER 1000 SQUARE FEET
- 3. 2.5 GALLONS OF ORGANIC TACKIFIER. 4. 92 GALLONS OF WATER (MINIMUM).
- F. THE WOOD FIBER MULCH, SEED, TACKIFIER AND WATER SHALL BE MIXED TOGETHER IN A HYDRO SEEDING MACHINE HAVING A CAPACITY OF AT LEAST 2,000 GALLONS TO ALLOW FOR A HOMOGENEOUS SLURRY WHICH IS THOROUGHLY MIXED AND CAN BE APPLIED EASILY WITHOUT CLOGGING. THE MACHINE SHALL BE MOUNTED ON A TRAVELING UNIT WHICH IS EITHER SELF-PROPELLED OR DRAWN BY A SEPARATE UNIT. EQUIPMENT USED IN THE HYDRO SEEDING PROCESS WILL BE THOROUGHLY CLEANED OF ALL SEED AND OTHER MATERIALS USED IN ANY PREVIOUS HYDRO SEEDING PROCESS, PRIOR TO HYDRO SEEDING ON THIS PROJECT.
- G. THE EQUIPMENT SHALL HAVE A BUILT—IN AGITATION SYSTEM AND OPERATING CAPACITY SUFFICIENT TO AGITATE, SUSPEND AND HOMOGENEOUSLY MIX A SLURRY CONTAINING NOT LESS THAN 44 LBS. OF ORGANIC MULCHING AMENDMENT PLUS CHEMICAL ADDITIVES AND SOLIDS FOR EACH 100 GALLONS OF WATER.
- H. THE SLURRY SHALL BE PREPARED AT THE SITE AND ITS COMPONENTS SHALL BE MIXED TO SUPPLY THE RATES OF APPLICATION AS SPECIFIED. SLURRY PREPARATION SHALL BEGIN BY ADDING WATER TO THE TANK WHEN THE ENGINE IS AT HALF (1/2) THROTTLE. THE ENGINE THROTTLE SHALL BE OPEN TO FULL SPEED WHEN THE TANK IS HALF (1/2) FILLED WITH WATER. ALL ORGANIC AMENDMENTS, FIBER AND CHEMICALS SHALL THEN BE ADDED BY THE TIME THE TANK IS TWO THIRDS (2/3) TO THREE FOURTHS (3/4) FULL. AT THIS TIME, SEED MIX SHALL ALSO BE ADDED AND NOT BEFORE THIS TIME, SPRAYING SHALL COMMENCE IMMEDIATELY WHEN THE TANK IS FULL AND THE SLURRY IS MIXED.
- I, APPLY HYDROSEED TO FORM EVEN APPEARING COVER OVER REQUIRED AREAS. THE SLURRY SHALL BE APPLIED IN A DOWNWARD DRILLING MOTION VIA A FAN STREAM NOZZLE, IT IS IMPORTANT TO ENSURE THAT ALL OF THE COMPONENTS ENTER AND MIX WITH THE SOIL. USE ONLY QUALIFIED AND TRAINED PERSONNEL TO ENSURE UNIFORMITY OF THE HYDROSEED APPLICATION.
- J. THE HYDRO SEEDING SLURRY COMPONENTS SHALL NOT BE LEFT IN THE HYDROSEED MACHINE FOR MORE THAN TWO (2) HOURS IN ORDER TO AVOID SEED DETERIORATION.



- (1) 2" DIA. x 10' STRAIGHT WOODEN STAKE (2 REQUIRED)
- (2) PREVAILING WIND DIRECTION
- (3) V.I.T. CINCH-TIE VINYL TREE TIE (2 PER STAKE, LENGTH AS REQ'D). SECURE TO STAKE W/GALV. NAIL, 1 PER TIE
- (4) 24" MIN.
- (5) SEE TREE/SHRUB PLANTING DETAIL
- (6) 6" MAX. (7) TREE TRUNK
- (8) ROOTBALL
- (9) 3" LAYER SHREDDED BARK MULCH AROUND EACH TREE IN 3' RADIUS CIRCLE (WHEN IN TURF)
- (10) 3x ROOTBALL DIA, MIN.



DOUBLE TREE STAKING



WEBER STATE UNIVERSITY PETERSON PLAZA

PLANTING NOTES

**PBINGHAM SENGINEERING** 

SALT LAKE CITY - (801) 532-2520 Chk: --OGDEN - (801) 399-1662 GHG 03/24/06 DFCM REVISIONS Created:01/01/01 | Proj. # 4365 Print Date: 03/24/2006 0 GHG 06/03/05 ISSUED FOR BID Copyright © 2003 Bingham Engineering, Inc. Drawing not to be reused in part or in whole without written permission. B GHG 05/13/05 ISSUED FOR REVIEW Rev. By Date Remarks P:\4365\4365-PROJECT\dwg\4365-PLANT-DET.dwg

